



National Environmental

12 Bessemer Road
Norwich
NR4 6DQ

Tel: 01603 663000 Email: lab@nationalenvironmental.co.uk

Bulk Sample Test Certificate



Customer: Stuart Doe	Order Number: n/a
Customer Address: [REDACTED]	
Site Address: [REDACTED]	
Sample/s Taken By: Stuart Doe	Report Number: J021632
No of Samples: 1	Report Issue Date: 04/04/2022
Technician's Name: Zoe Bye	Date of Analysis: 04/04/2022
Location where laboratory analysis completed: Norfolk	

SAMPLE No.	CLIENT REF. Number	SAMPLE DETAILS	ASBESTOS TYPE(S) PRESENT
1	BS056599	cement product	Chrysotile
		END	

KEY : N.A.D.I.S = NO ASBESTOS DETECTED IN SAMPLE

AUTHORISED SIGNATORY

NAME / POSITION Zoe Bye - Lab Analyst

STATEMENT OF CERTIFICATION
This is to certify that analysis has been carried out to determine the presence of asbestos fibres using Polarised Light Microscopy and Dispersion Staining techniques. The in house methods used are UKAS accredited and in accordance with in house procedure TPD002 and the HSE HSG248, The analysts guide for sampling, analysis and clearance procedures, Appendix 2: 'Asbestos in bulk materials: Sampling and identification by polarised light microscopy' (PLM). When the Test Certificate indicates sample(s) taken by the customer, the following disclaimers apply: They are outside the scope of our UKAS accreditation for sampling. The customer provided all site address and sample details information. National Environmental Limited cannot accept responsibility for the accuracy of information provided by the customer or whether the sample(s) taken were representative of the material sampled.
BA007 VER4 27-JAN-21 QCM
ACCREDITED BY UKAS FOR ANALYSING FOR ASBESTOS WITHIN BULK MATERIALS